

Certificate No. 201501132

KFI

CERTIFICATE OF TYPE APPROVAL

Applicant : You Jeongmoo

Company : IRTKorea Co.,Ltd

Address : 609, Ace Apartment Factory, 234, Galmachi-ro, Jungwon-gu, Seongnam-si,
Gyeonggi-do, Korea

This is to certify that the following item has been approved in accordance with the provisions of Article 36-① and 37-① of The Installation, Maintenance, and Safety Control of Fire-Fighting System Act, and Article 8 and 9-③ of The Rules on Quality Control, ect. of Fire-Fighting Appliances.

1. Item : Flame Detector
2. Type : DC 24 V, Normal Type, Restorable Type, Waterproof Type, Indoor/Outdoor Type, UV/IR Type, Viewing angle 90°, Nominal monitoring distance 40 m(Model : IR-3Digital_UV)
3. Approval No. : 감15-54
4. Limitation : —

Date : November 30, 2015

Choi, Ung-Gil

President

Korea Fire Institute